



June 20, 2006

DEPARTMENT OF COMMERCE
SAFETY AND BUILDINGS
LYNITA DOCKEN
4003 N KINNEY COULEE RD
LA CROSSE WI 54650

Re: Description: POOL - INTERNAL POOL WALL FOR STEPS, ALTERNATE POOL SYSTEM
Manufacturer: DEPARTMENT OF COMMERCE
Product Name: INTERNAL POOL WALL FOR STEPS
Model Number(s): NONE
Product File No: 20060297

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 90.09 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2011.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The wall is a maximum of 18 inches in width.
- The wall extends into the pool no more than one foot beyond the termination of the steps.
- The wall includes a code compliant handrail on the step side of the wall.
- The wall is installed so as to be above the high water level in the pool.
- The top of the wall is constructed so as to be slip resistant.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

James H. Miller
Section Chief, Bureau of Integrated Services
Phone: 608-266-8072 Fax: 608-267-956